

## TEST CONFIRMATION

according to elastomer guideline extended transitional rule concerning the examination of flat gasket material samples "sheets produced with KLINGERSIL® C-4430" in accordance with the guideline for hygienic assessment of elastomers in contact with drinking water (Elastomer Guideline) of Umweltbundesamt (UBA)

Manufacturer:	Rich. Klinger Dichtungstechnik GmbH & Co. KG, Gumpoldskirchen, Österreich
Type of the test material:	flat gasket material
Brand Name of the test material:	"sheets produced with KLINGERSIL® C-4430"
Type of the sample:	sheets
Samples received:	15.05.2020
Sampler:	manufacturer
TZW-reference-no.:	KA 0082/20

### Test results

1. Material composition: was given under KC 698/19 and approved
2. Migration test:  
Cold water 23°C: requirements kept  
Hot water 85°C: requirements kept  
Test results see Prüfzeugnis KA 0082/20 of 15.10.2020
3. Summary:  
The examined flat gasket material samples "sheets produced with KLINGERSIL® C-4430" comply with the requirements of the Elastomer Guideline of Umweltbundesamt (UBA) (Bundesgesundheitsblatt current version) in the complete range of gaskets.

### Remarks:

This confirmation expires on 31.12.2021.

Reference to the original German text is recommended if necessary.

Karlsruhe, 12.01.2021



Dr. J. Ruppert / i.V. B. Stulz  
Head of the Test Centre

The publication of this test confirmation - completely or in parts - is not permitted except of written approval by the test centre