

TEST CONFIRMATION

according to elastomer guideline extended transitional rule concerning the examination of flat gasket material samples "sheets produced with KLINGERSIL® C-4400, green" in accordance with the guideline for hygienic assessment of elastomers in contact with drinking water (Elastomer Guideline) of Umweltbundesamt (UBA)

Manufacturer: Rich. Klinger Dichtungstechnik GmbH & Co. KG, Gumpoldskirchen, Österreich
Type of the test material: flat gasket material
Brand Name of the test material: "sheets produced with Klingersil® C-4400 (green)"
Type of the sample: sheets
Samples received: 31.10.2019
Sampler: manufacturer
TZW-reference-no.: KA 0328/19

Test results

1. Material composition: was given under KC 699/19 and approved

2. Migration test: cold water 23°C: requirements kept
Test results see test certificate KA 328/19 of 18.02.2020

3. Summary:

The examined flat gasket material samples "sheets produced with KLINGERSIL® C-4400, green" comply with the requirements of the Elastomer Guideline of Umweltbundesamt (UBA) (Bundesgesundheitsblatt current version) in the complete range of gaskets.

St

Remarks:

This confirmation expires on 31.12.2021.
Reference to the original German text is recommended if necessary.

Karlsruhe, 28.07.2020



Dr. J. Klinger / i.V. Dr.-Ing. R. Turković
Head of the Test Centre

The publication of this test confirmation - completely or in parts - is not permitted except of written approval by the test centre