

# TEST CERTIFICATE

for tests according to DVGW standard W 270 (11/2007) "Promotion of microbial growth on materials coming into contact with drinking water - examination and assessment".

Manufacturer: Rich. Klinger Dichtungstechnik GmbH & Co. KG, Gumpoldskirchen Österreich

Test item: test plates, flat gasket quality

Name of material: KLINGERSIL® C4240

Date of reception: 14.06.2021

Samples taken by: manufacturer

TZW-reference no.: 5-1238/21

The presented material KLINGERSIL® C4240 complies with regard to microbiological aspects with the requirements of DVGW standard W 270 (11/2007) for small sized sealings.

The detailed test results are given in a separate test report.

The validity is fixed by other instructions and expires on 17.11.2026 at the latest.

The test certificate becomes invalid if the material composition or manufacturing process has been changed.

The test certificate is based on the first test (TZW ref.-no. 5-0724/21).

The measurement uncertainty of the test laboratory is not taken into consideration in the declaration of conformity.

Karlsruhe, 15.12.2021



Dr.-Ing J. Ruppert / p.p. B. Stulz  
Head of Test Centre

The publication of this test certificate - completely or in parts - is not permitted except of written approval by the test centre