

TEST CERTIFICATE

for tests according to DVGW standard W 270 (11/2007)

Manufacturer: Rich. Klinger Dichtungstechnik GmbH & Co. KG, Gumpoldskirchen, Österreich

Test item: test plates, flat gasket-quality

Name of material: KLINGERSIL® C-4430

Date of reception: 23.09.2019

Samples taken by: manufacturer

TZW-reference no.: MO 193/19

The presented material KLINGERSIL® C-4430 complies with regard to microbiological aspects with the requirements of DVGW standard W 270 (11/2007).

The detailed test results are given in a separate test report.

The validity is fixed by other instructions and expires on 31.12.2021 at the latest.

The test certificate becomes invalid if the material composition or manufacturing has been changed.

Karlsruhe, 31.01.2020



Dr. J. Klinger / i.V. Dr.-Ing. R. Turković
Head of the Test Centre

The publication of this test certificate - completely or in parts - is not permitted except of written approval by the test centre