

Approval Number 250155028
Test Report: J-00492489



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

16th January 2025

Rich. Klinger Dichtungstechnik GmbH & Co. KG
Am Kanal 8-10,
A - 2352 Gumpoldskirchen,
Austria

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE- THESE MATERIALS ARE FOR USE ONLY AS A JOINTING/GASKET MATERIAL HAVING BEEN TESTED AT 5075 REDUCED SURFACE AREA TO VOLUME RATIO.

'KLINGERSIL® C-4430'. NBR/fibre gasket material, which is green coloured one side and white coloured the other, manufactured by calandring. For use with water up to 85°C.

For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 250155028
APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO. KG

The Scheme reserves the right to review approval.
Approval 250155028 is valid between January 2025 and January 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

Ian Hughes
WRAS Approvals Manager