



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5123CN0325

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Rich. Klinger Dichtungstechnik GmbH & Co KG Am Kanal 8-10, A-2352 Gumpoldskirchen
Distributor <i>Vertreiber</i>	Rich. Klinger Dichtungstechnik GmbH & Co KG Am Kanal 8-10, A-2352 Gumpoldskirchen
Product Category <i>Produktart</i>	Greasing and sealing materials: Flat sealing materials on synthetic fiber basis (5123)
Product description <i>Produktbezeichnung</i>	Flat sealing material on synthetic fiber basis
Model <i>Modell</i>	KLINGERSil® C-4430 plus
Test reports <i>Prüfberichte</i>	Supplement test: 24-00350-AB01 from 19.02.2025 (EBI) Type testing: 12/136/5123/1 from 25.07.2012 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN 3535-6 (01.04.2019) DVGW CERT ZP 5123 (22.04.2024)- as far as applicable

Date of Expiry / File No. 25.07.2027 / 25-0094-GNA
Ablaufdatum / Aktenzeichen

27.06.2025 Bd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category	Remarks
<i>Gasart</i>	<i>Bemerkungen</i>
Fuel gases according to G 260	2nd and 5th gas families

Type	Technical Data	Remarks
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>
KLINGERSil® C-4430 plus	Designation according to standard: DIN 3535-FA	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

The flat gasket material is tested according to DVGW CERT ZP 5123 with 100% hydrogen by volume.
The specific volumetric leakage rate when tested with pure hydrogen at 0 °C, 1013.25 hPa and a medium
Sealing circumference of 0.22 m is 7,03 cm³/(m*min).